

555.633.01

date of issue: 03-02-2014



Certificateholder
Karcher GmbH
Raiffeisenstrasse 32
D-74906 Bad Rappenau
T : +49 7264 91 64 -0
F : +49 7264 91 64 -40
E : mail@karcher-design.de
I : www.karcher-design.de



Declaration of SKG

This certificate is in accordance with the SKG Regulations approval, product certification and process certification: 2011.

SKG declares that the by or on behalf of the certificate owner produced building hardware product:
long plate

delivered under logo / brand:
Karcher

delivered under type- and / or article number:
ESG675 PZ 71, ESG650N PZ 71

meets class 3 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

SKG

bezoekadres
Nieuwe Kanaal 9F
6709 PA Wageningen

postadres
Postbus 362
6700 AJ Wageningen

T 0317 - 421 720
F 0317 - 421 677
E info@skg.nl
I www.skg.nl

For SKG

ir. H.A.J. van Dartel
Certification manager

Verify at www.sterrenwijzer.nl if this certificate is still valid and actual.

This certificate has 2 pages

SKG productcertificate

Karcher GmbH

Number: 555.633.01

page 2 of 2

1. PRODUCT

long plate

MAIN GROUP

security furniture

2. TECHNICAL SPECIFICATION:

Construction: 1 set of an outside part and an inside part with mounting screws

Operating / System: square or rounded; various 17 mm cylinder holes; various handles

Material: outside and inside part: steel zinc coated with stainless steel cover

Dimension: outside part: 255x54x15 mm; inside part: 255x53x5 mm

Fixing: 2x M* + 1x M6 in steel cams

Intended use: in combination with mortice locks on doors

3. DELIVERY

The delivery includes an installation instruction:
version 01-13-11-2013

4. PERFORMANCES

A long plate according this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this long plate is installed according the installation instructions of the certificate holder meets burglar resistance class (RC) 3 STER of NEN 5096 and EN 1627, if:

- the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled. Remark: In façade elements in accordance with a burglar resistance class (RC) of EN 1627 only SKG*** cylinders are applicable.

A window or door, in existing buildings, in which this long plate is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

- the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).
-